



Ref. Certif. No.

**SE-106962****IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Switch-disconnectors

Name and address of the applicant

Zhejiang ETEK Electrical technology Co., Ltd.  
No. 288 Wei 17th Road, Yueqing Economic Development Zone,  
Yueqing, Wenzhou, Zhejiang China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EKD2-125

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

211102689SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden**intertek**

Signature:

Quan Li

Date: 24 January, 2022

**Rating and principal characteristics**

$U_e=230/240V\sim(1P)$ ,  $400/415V\sim(2,3,4P)$ , 50/60Hz

$I_e=25, 32, 40, 50, 63, 80, 100, 125A$ , Cat. AC-22A

$U_i=500V$ ,  $U_{imp}=6kV$

$I_{cw}=2000A/1s$ ,  $I_{cm}=3000A$ .

Date: 24 January, 2022

Signature: 