

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

RCCB, residual current operated circuit-breaker without integral overcurrent protection, functionally independent of line voltage

Name and address of the applicant

ZHEJIANG ETEK Electrical Technology CO.,LTD.
NO.288, Wei 17th Road, Yueqing Economic Development Zone, 325600 Yueqing, Wenzhou, Zhejiang CHINA

Name and address of the manufacturer

ZHEJIANG ETEK Electrical Technology CO.,LTD.
NO.288, Wei 17th Road, Yueqing Economic Development Zone, 325600 Yueqing, Wenzhou, Zhejiang CHINA

Name and address of the factory

ZHEJIANG ETEK Electrical Technology CO.,LTD.
NO.288, Wei 17th Road, Yueqing Economic Development Zone, 325600 Yueqing, Wenzhou, Zhejiang CHINA

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

Ue : AC 230 V / 240 V (1P+N)
AC 400 V / 415 V (3P+N)

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

EKL1-63B

Additional information (if necessary may also be reported on page 2)

see further ratings on page 2

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010
IEC 61008-1:2010/AMD1:2012
IEC 61008-1:2010/AMD2:2013
IEC 61008-2-1:1990
IEC 62423:2009

As shown in the Test Report Ref. No. which forms part of this Certificate

286311-TL3-1

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH

VDE Testing and Certification Institute

Zertifizierungsstelle und internat. Angelegenheiten

Certification Body and internat. Affairs

Date: 2021-12-09

Signature:

R. Nickel

Additional information (if necessary)

Further ratings and principal characteristics:

50/60 Hz

In: 16 A; 20 A; 25 A; 32 A; 40 A; 63 A

I Δ n: 30 mA; 100 mA; 300 mA

Behaviour in presence of d.c. components: Type B

Inc: 10 kA

I Δ m: 500 A (In = 16,20,25,32,40 A); 630 A (In = 63 A)

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
 Zertifizierungsstelle und internat. Angelegenheiten
 Certification Body and internat. Affairs

Date: 2021-12-09

Signature:


 R. Nickel