



Ref. Certif. No.

SE-96346

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

CB TEST CERTIFICATE

Product

Residual current operated circuit-breaker with integral overcurrent protection for household and similar uses (RCBO's)

Name and address of the applicant

Zhejiang ETEK Electrical technology Co., Ltd.
No. 288 Wei 17th Road, Yueqing Economic Development Zone
Yueqing, Wenzhou, Zhejiang Province
China

Name and address of the manufacturer

Wenzhou Junyi Electric Co, Ltd.
Hudong Village, Liushi Town, Yueqing City, Wenzhou,
Zhejiang Province,
China

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as manufacturer

Ratings and principal characteristics

See page 2

Trademark (if any)

ETEK

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

EKL9-40, EKL9-40H

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2
IEC 61009-2-2:1991

As shown in the Test Report Ref. No. which forms part of this Certificate

191100735SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 4 December 2019

intertek

Signature:


Henrik Wikström

Ratings and principal characteristics

$U_n = 240V(230V)\sim(1P+N)$, 50/60Hz

$I_n = 6, 10, 13, 16, 20, 25, 32, 40A$; B- & C- Type

$I\Delta n = 0,01A, 0,03A, 0,1A, 0,3A$; Type-A & AC

$I_{cs} = 7500A$, $I_{cn} = 10000A$ for EKL9-40H

$I_{cs} = I_{cn} = 6000A$ for EKL9-40

Energy limiting class 3 (only for $I_{cs} = I_{cn} = 6000A$)

$I\Delta m = 6000A$

Date: 4 December 2019

Signature:

