



Ref. Certif. No.

FR_712026

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breaker
MCB

Name and address of the applicant

ZHEJIANG ETEK Electrical technology CO.,LTD
NO.288 Wei17th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zheijang Province - China

Name and address of the manufacturer

ZHEJIANG ETEK Electrical technology CO.,LTD
NO.288 Wei17th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zheijang Province - China

Name and address of the factory

ZHEJIANG ETEK Electrical technology CO.,LTD
NO.288 Wei17th Road, Yueqing Economic Development Zone,
Yueqing, Wenzhou, Zheijang Province - China


Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015 +A1:2019

As shown in the Test Report Ref. No. which forms part of this Certificate

B200069

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 19/08/2021

Signature: 
Certification Officer

ANNEX

EKM1-40N 1P+N		Icn=lcs=6000A
1A	Type C	EKM-06C01
2A	Type C	EKM-06C02
3A	Type C	EKM-06C03
4A	Type C	EKM-06C04
6A	Type C	EKM-06C06
10A	Type C	EKM-06C10
16A	Type C	EKM-06C16
20A	Type C	EKM-06C20
25A	Type C	EKM-06C25
32A	Type C	EKM-06C32
40A	Type C	EKM-06C40

EKM1-40N 1P+N		Icn=lcs=6000A
1A	Type B	EKM-06B01
2A	Type B	EKM-06B02
3A	Type B	EKM-06B03
4A	Type B	EKM-06B04
6A	Type B	EKM-06B06
10A	Type B	EKM-06B10
16A	Type B	EKM-06B16
20A	Type B	EKM-06B20
25A	Type B	EKM-06B25
32A	Type B	EKM-06B32
40A	Type B	EKM-06B40



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 19/08/2021



Signature: **Gilles LEMONNIER**
 Certification Officer

ANNEX

Rated operational voltage U_e : (V)	220/230/240V(1P+N)
Rated current I_n : (A)	1;2;3;4;6;10;16;20;25;32;40A
Rated frequency : (Hz)	50/60Hz
Nature of supply :	~
Total number of poles :	1P+N
Number of protected poles :	1P
Rated insulation voltage U_i : (V)	500V
Rated impulse withstand voltage U_{imp} : (V)	4000V
Instantaneous tripping current :	B and C
Reference ambient calibration air temperature : (°C)	30
Rated short-circuit capacity I_{cn} : (A)	6000A
Rated making and breaking capacity on one pole separately I_{cn1} : (A)	6000A
Energy limiting class I^2t :	3
Grid distance (short-circuit tests) :	50mm
Protection against external influences :	Enclosed
Protection degree :	IP20
Material group :	IIIa
Method of mounting :	On rail
Method of electrical connection	
not associated with the mechanical-mounting	
Type of terminals :	Pillar terminal
Nominal diameter of thread : (mm)	3.9mm
Operating means :	Lever



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 19/08/2021



Signature: **Gilles LEMONNIER**
 Certification Officer