

## **ATTESTATION** of conformity with European Directives

Product: MCB

Reference EKM2-32N

Issued to ZHEJIANG ETEK Electrical technology CO.,LTD.

Address NO.288 Wei17th Road, Yueqing Economic Development Zone

Yueqing, Wenzhou, Zheijang Province, P.R. China

Manufacturer Hangzhou Taimu Electrical Co., LTD.

Type D,C and B

Ue=230V(1P+N neutral on left) In=1;2;3;4;6;10;16;20;25;32A

Icn=Ics=Icn1=6000A

Technical characteristics Icn=Icn1=10000A Ics=7500A

Energy limit class: 3(Type B and C) (according to EN 60898-1)

Grid distance: 45mm

Ui=500V Uimp=4kV

Screw diameter=3,9mm

The submitted sample of the above equipment has been tested for  $\mathsf{CE}$  marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60898-1:2019	B200045	2020-07-10

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product The  $C \in \mathbb{R}$  marking may be affixed if all relevant and effective European Directives with  $C \in \mathbb{R}$  are applicable

Shanghai (P.R. China), July 24th, 2020.

CE

Charlie CHEN Product Line Manager

rnis αοcument snaii not be reproduced, except in full, without the written approval of BV LCIE China. Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road, CaoHejing Songjiang High-Tech Park, Shanghai P.R.C (201612) Tel: +86 21 6195 7000 Fax: +86 21 6195 7001 Email:contact@cn.bureauveritas.com