



ATTESTATION of conformity with European Directives

Product: Motor protective circuit breaker
Reference EKMS2 Series
Issued to ZHEJIANG ETEK Electrical technology CO.,LTD
Address NO.288 Wei17th Road,Yueqing Economic Development Zone
 Yueqing, Wenzhou, Zhejiang Province, China
Manufacturer YUE QING SHI SUNCOME ELECTRIC CO., LTD.
 Ue: 3P(380/400/415V~) 50/60Hz
 Utilization category: A-3
 Ie: 0,1 to 32A(Details see page 8 and 9)
 Icu: See page 9
Technical characteristics Ics: See page 9
 Ui= 690V Uimp=6kV
 IP20
 Pollution degree: 3
 Type of terminals: Screw

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-1:2007 + A1:2011 + A2:2014 EN 60947-4-1:2019	B190081	2020-01-06

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), January 16th, 2020.



Charlie CHEN
 Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.