



APPROVALS®

Certificate of Approval

Certificate No.: SAA-180108-EA

Certificate Holder: Zhejiang Etek Electrical Technology Co., Ltd
NO.288 Wei 17th Road,
Yueqing Economic Development Zone
Yueqing, Wenzhou,
Zhejiang Province,
P.R. China

Class Description: Residual Current Device
Product Description: RCBO
Brand Name: ETEK
Model No.: EKL4-40L
Markings: $U_e=240V\sim 50/60Hz$ Type A & AC
 $U_{imp}=4kV$
 $I_n=6, 10, 16, 20, 25, 32, 40A$ Type B and C
 $I_{cn}=I_{cs}=6000A,$
 $I_{\Delta n}=500A$
 $I_{\Delta n}=10, 30mA$
Standard: AS/NZS 61009.1:2015
Conditions: Nil

Approval Mark: SAA-180108-EA or RCM

Date First Registered: 19 January 2018
Date of Expiry: 19 January 2023


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 19-01-18 180108/1